

PHASE 1 AND 2



WARNING: OVERHEAD POWER CABLES

As the Contractor you should be aware of your responsibilities under the Electricity at Work Regulations 1989 to safeguard your employees and other persons who are working on the site. You are also expected to follow the recommendations set out in the Health and Safety Executive Guidance Note GS6. The following applies to this site.

The vertical clearance of conductor to ground is 7.10 metres.

The vertical reach of equipment must not exceed 5.30 metres.

The maximum height of any structure (or stationary vehicle) beneath an overhead line on which a person may stand must not exceed 2.90 metres.

If any machine can reach in excess of the 5.30 metres it shall not come closer to the nearest conductor than the vehicle maximum reach plus 6.00 metres.

If long reach equipment/long objects are to be used additional precautions must be taken in accordance with HSE Guidance Note GS6 to ensure that the above clearances are not encroached upon.

EDF Energy Networks, Mr Paul Harvey, Tel: 08701 962166

REV	DESCRIPTION	ID	CHK'D	DATE
B	ISSUED FOR TENDER	PJT	CHK'D	17/03/08

P. J. Townsend Associates
 12 Hill Rise
 St Ives
 Cambridgeshire
 PE27 6SP
 Telephone: 01480 353216
 E-Mail: p.jta@ntworld.com



ARCHITECTURE - ENGINEERING - PROJECT MANAGEMENT

CLIENT/CUSTOMER
 ST. IVES TOWN COUNCIL

PROJECT
 EXTENSION TO THE
 RAMSEY ROAD CEMETERY

TITLE
 SETTING OUT, LEVELS AND GENERAL
 ARRANGEMENT: PHASE 1 & 2

DRAWN	SCALE	DATE
PJT	1:100@A1	27/11/07

DRAWING NUMBER	ISSUE
070727/3	B

DO NOT SCALE FROM THIS DRAWING, IF IN DOUBT ASK.

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE CAMBRIDGESHIRE COUNTY COUNCIL HOUSING ESTATE ROAD CONSTRUCTION SPECIFICATION AND ALL OTHER PJTA DRAWINGS & DETAILS.